

Water Testing Documentation for 2014--Alliance Education Center

<u>Range of Test</u>		<u>Pos/Neg</u>	<u>Pos/Neg</u>	<u>Pos/Neg</u>	<u>0-50 ppm</u>	<u>0-10 ppm</u>	<u>6.0-10 ppm</u>	<u>0-425 ppm</u>	<u>0-10 ppm</u>
<u>Desired or Ideal</u>		Negative	Negative	Negative	Below 10.0 ppm	Below 1.0 ppm	6.5-8.5 ppm	50 ppm or less	Below 4 ppm
<u>Start Date</u>	<u>Room</u>	<u>PB/Lead</u>	<u>E.coli/ Bacteria</u>	<u>Pesticides</u>	<u>Nitrates/ Nitrites</u>	<u>Nitrites</u>	<u>pH</u>	<u>Hardness</u>	<u>Chlorine</u>
10/16/2014	101	Negative	Negative	Negative	0.5	0.0	8.5	250	0
10/16/2014	102	Negative	Negative	Negative	0.5	0.0	8.5	250	0
10/16/2014	103	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/16/2014	104	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/16/2014	105	Negative	Negative	Negative	0.0	0.0	7.5	250	0
10/16/2014	106	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/16/2014	107	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/20/2014	108	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/20/2014	109	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/20/2014	110	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/20/2014	111	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/20/2014	112	Negative	Negative	Negative	0.5	0.0	8.5	250	0
10/20/2014	113	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/20/2014	114	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	Girls Bathroom 1	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	Girls Bathroom 2	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	Boys Bathroom 1	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	Boys Bathroom 2	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	West Drinking	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	East Drinking	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	Staff Workroom	Negative	Negative	Negative	0.0	0.0	8.5	250	0
10/14/2014	Staff Workrm. Bat	Negative	Negative	Negative	0.5	0.0	8.5	250	0
10/14/2014	FACS - N	Negative	Negative	Negative	0.5	0.0	8.5	250	0
10/14/2014	FACS - S	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	Activity Ctr. Drinking	Negative	Negative	Negative	0.5	0.0	7.5	250	0
10/14/2014	Conference B	Negative	Negative	Negative	0.0	0.0	7.5	250	0
10/14/2014	Fitness Drinking	Negative	Negative	Negative	0.5	0.0	7.5	250	0

10/14/2014	Kitchen 1	Negative	Negative	Negative	0.5	0.0	8.5	250	0
------------	-----------	----------	----------	----------	-----	-----	-----	-----	---